# North County Fire Authority

**Serving the Cities of Brisbane, Daly City, Pacifica**

Ron D. Myers
Fire Chief

25 Park Place, Suite B
Brisbane, CA 94005

Administration
Phone 650-800-6580


## Underground Tank Removal Requirements for the cities of Brisbane, Daly City and Pacifica:

- You must have a permit from San Mateo County Environmental Health for an underground tank removal.
- Also apply for a fire department permit for the tank removal. Permits can be applied for at our administrative office located at 10 Wembley Dr. Daly City. 650-991-8138. Fees for this permit can be found on the Business Assistance page under Fees.
- A Fire Inspector must be on site with SMC Environmental Health during the actual removal.
- Tanks must be inerted and verified with a meter before removal.
- A 2A-10BC rated fire extinguisher with a current service tag attached must be on site.